


NOTES:

1. ALL PIPING FROM TAP THROUGH VAULT SHALL BE DUCTILE IRON PIPE.
2. INSTALL FIRE HYDRANT 5' INSIDE RIGHT-OF-WAY OR AS DIRECTED BY THE CITY.
3. ACCESS EASEMENT SHALL BE MIN. 20'X20'.
4. LOCATE FIRE DEPARTMENT CONNECTION (FDC) 40' (MIN.) FROM BUILDING WITH 3' (MIN.) CLEARANCE FROM ALL SIDES OF ANY OBSTRUCTIONS AND SHALL BE IN ACCORDANCE WITH STATE FIRE CODES AND MUST BE APPROVED BY THE CITY FIRE CHIEF. FDC SHALL BE FREE-STANDING SIAMESE TYPE.

CONNECTION PLAN		
	FIRE VAULT DETAIL	
	SCALE: NONE	FV-1
	DATE: 4-16-20	